



(2) 20 AMP SMALL APPLIANCE CIRCUITS GFCI CEC 210-52(C)(1) COUNTERS WIDER THAN 12" NEED A RECEPTACLE OUTLET. NO POINT ALONG THE WALL LINE CAN BE MORE THAN 24" FROM RECEPTACLE OUTLETS. + 42" ABV FLR

IF MICRO-WAVE, PROVIDE DEDICATED 20 AMP CIRCUIT OUTLET +78" ABV FLR

PROVIDE GENERAL WALL OUTLETS LOCATED IN SUCH THAT NO POINT ALONG A WALL IS MORE THAN 6' FROM AN OUTLET (EACH DOORWAY STARTS A NEW WALL AREA). A WALL IS DEFINED AS AN AREA 2' WIDE. CEC 210.52(A).